



DATE 2018-07-31	TECHNICIAN Darren Mann	JOB/ORDER # 8701	REFERENCE TEXT
FIRST NAME Hsing		LAST NAME Jou	
BILLING ADDRESS MS. 503 - 1010 HOWE ST VANCOUVER, V6Z 1P5 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 503 - 1010 HOWE ST VANCOUVER, V6Z 1P5 BRITISH COLUMBIA, CANADA	
PHONE 7807107431		EMAIL htt.jou@gmail.com	

REASON FOR TODAY'S CALL:
 toilet leaking out bottom. might need new seals? *caretaker will grant access. Rob: 778.994.7399

DESCRIPTION OF WORK PERFORMED:
 The toilet was leaking from between the tank and the bowl when flushed. This water would run down the back of the toilet and along the floor toward the front of the toilet. I also found the flapper to be warped, the lever handle to be broken, and the fillvalve was spraying out of the top. I removed the tank, installed a new tank to bowl gasket, fillvalve, flapper, tank lever; and reinstalled with new tank bolts and braided supply line. Tested and no other leaks detected.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		TOILT TANK REBUILD - STANDARD	\$199.00	\$199.00
			SUBTOTAL:	\$199.00
			GST (5%):	\$9.95
			TOTAL:	\$208.95

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY
LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2018-07-31

 CUSTOMER SIGNATURE

 DATE