



DATE 2019-04-26	TECHNICIAN Darren Mann	JOB/ORDER # 9345	REFERENCE TEXT Client reference
FIRST NAME Adam	LAST NAME Stanton		
BILLING ADDRESS COMPANY / BILLING NAME 1810 - 939 EXPO BLVD VANCOUVER, V6Z3G7 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 1810 - 939 EXPO BLVD, BUZZER 1427 VANCOUVER, V6Z3G7 BRITISH COLUMBIA, CANADA	
PHONE 1.403.999.3969		EMAIL adamstantonmusic@gmail.com	

**REASON FOR TODAY'S CALL:**  
 Toilet tank not refilling after flush. Toilet supply line nut broken.

**DESCRIPTION OF WORK PERFORMED:**  
 I replaced the FillValve and supply line and tested.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace toilet FillValve - standard	\$159.00	\$159.00
			<b>SUBTOTAL:</b>	\$159.00
			<b>GST (5%):</b>	\$7.95
			<b>TOTAL:</b>	\$166.95

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

**WARRANTY:** **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2019-04-26

CUSTOMER SIGNATURE

DATE