



DATE 2012-07-04 09:00 am	TECHNICIAN darren mann	JOB/ORDER # 320	REFERENCE TEXT
FIRST NAME Suzanne		LAST NAME Feeney	
BILLING ADDRESS  1072 AVENUE ROAD TORONTO, M5N2C9 ONTARIO, CANADA		SERVICE ADDRESS  #2201 - 583 BEACH CRESCENT VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 1.647.780.2960		EMAIL suzanne_c9@hotmail.com	

REASON FOR TODAY'S CALL:  
 -leak under lav sink

DESCRIPTION OF WORK PERFORMED:  
 -found leak to be coming from a loose connection in the drainage, i tightened this connection but issue persisted. -replaced ABS drain piping under lav sink -toilet was slow to fill after each flush, replaced toilet fillvalve.

TECHNICIAN RECOMMENDATIONS:  
 -as per your request i took a look around the toilet and saw no signs of moisture collecting or condensation buildup:)

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
2 h 00 m		Labour	\$99.00	\$198.00
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ	\$25.00	\$25.00
1		ABS Fittings & Pipe	\$15.00	\$15.00

SUBTOTAL:	\$238.00
HST (12%):	\$28.56
TOTAL:	\$266.56

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

\_\_\_\_\_  
 CUSTOMER SIGNATURE

2012-07-04  
 \_\_\_\_\_  
 DATE