

(E) @SimplyPlumbing f YaletownPlumbing

## HST #837181627

DATE 2015-08-26	TECHNICIAN Darren Mann		JOB/O 5196	RDER #	REFERENCE TEXT Client reference
FIRST NAME SERENA		LAST NAME CHEN	7		
BILLING ADDRESS COMPANY / BILLING NAME 2355 WEST BROADWAY VANCOUVER, V6K 2E6 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS #305 - 2355 WEST BROADWA VANCOUVER, V6K 2E6 BRITISH COLUMBIA, CANADA	
PHONE 778-828-2036				EMAIL OHHELLOSERENA@GMAIL.C	ом

REASON FOR TODAY'S CALL:

-2 running toilets.

## DESCRIPTION OF WORK PERFORMED:

-1st bathroom(to right of entrance): I replaced the toilet fillvalve, flapper, and supply line. I also installed a new toilet seat and shower head(customer supplied). -2nd bathroom: i replaced the flapper but the toilet tank continued to leak into the bowl, I reinstalled the existing flapper and properly connected the chain and it now seems to be flushing as normal.

## **TECHNICIAN RECOMMENDATIONS:**

If the issue in the second bathroom toilet arises again I suggest the tank be removed and re-installed with a new tank to bowl gasket, tank bolts, flushvalve assembly, and supply line.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Toilet Fill-Valve, Flapper, Supply - Standard	\$169.00	\$169.00
0	WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY		SUBTOTAL:	\$169.00
<b>Give us Feedback</b> Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your		LABOUR - 1 YEAR ON NEW LINITS 30 DAYS ON REPAIR VOID AFTER 30 DAYS IF	GST (5%):	\$8.45
			TOTAL:	\$177.45
	t tell us how w	MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN,		
		2015-08-26		
		CUSTOMER SIGNATURE DATE		