



DATE 2016-10-05	TECHNICIAN Darren Mann	JOB/ORDER # 6511	REFERENCE TEXT Client reference
FIRST NAME John		LAST NAME Shepherd	
BILLING ADDRESS COMPANY / BILLING NAME 2935 WEST 33RD AVE VANCOUVER, V6N 2G4 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 2935 33RD AVE W VANCOUVER, V6N 2G4 BRITISH COLUMBIA, CANADA	
PHONE 603.374.2005		EMAIL shepherds@shaw.ca	

REASON FOR TODAY'S CALL:  
 Ground Floor Powder Room: replace gasket on Geberit (tank behind wall with very small opening!) toilet. Toilet is running intermittently and more and more. WE HAVE THE GASKET ALREADY.

DESCRIPTION OF WORK PERFORMED:  
 I replaced the flushvalve gasket and rinsed out the FillValve diaphragm. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace FlushValve Gasket - Geberit In-Wall	\$159.00	\$159.00

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2016-10-05

CUSTOMER SIGNATURE

DATE

SUBTOTAL:	\$159.00
GST (5%):	\$7.95
TOTAL:	\$166.95