



DATE 2017-02-22	TECHNICIAN Darren Mann	JOB/ORDER # 7027	REFERENCE TEXT 17-0263
FIRST NAME Advent		LAST NAME Admin	
BILLING ADDRESS ADVENT REAL ESTATE SERVICES LTD. #204 - 1168 HAMILTON ST VANCOUVER, V6B2S2 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 1104 - 1030 WEST BROADWAY MEAGHAN: 1.905.321.4528 NO BUZZ VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.736.6478		EMAIL andrea@adventvancouver.com	

REASON FOR TODAY'S CALL:  
toilet not filling correctly

DESCRIPTION OF WORK PERFORMED:  
The flapper was warped and the fillvalve was inconsistent in the levels it would fill the tank after each flush. I replaced the fillvalve, flapper, and supply line. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Discount Labour	\$99.00	\$99.00
1	2121352	B1-16DL 3/8X20 SPEEDI+ WC CONN	\$11.00	\$11.00
1	2465350	214L HORNET UNIV FLAPPER RBR	\$10.00	\$10.00
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ	\$35.00	\$35.00

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$155.00
GST (5%):	\$7.75
<b>TOTAL:</b>	<b>\$162.75</b>

\_\_\_\_\_ 2017-02-22  
 \_\_\_\_\_  
 CUSTOMER SIGNATURE DATE