



9516

HST #837181627

DATE 2017-11-20	TECHNICIAN Darren Mann	JOB/ORDER # 7937	REFERENCE TEXT Client reference
FIRST NAME Easyrent		LAST NAME Admin	
BILLING ADDRESS EASYRENT REAL ESTATE SERVICES LTD. 100 - 1290 HOMER ST VANCOUVER, V6B2Y5 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 3107 - 111 WEST GEORGIA ST CEDRIC: 604.782.3133 SANDRA: 778.233.3674 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.662.3279		EMAIL info@easyrent.ca	

REASON FOR TODAY'S CALL:
toilet lever handle broken.

DESCRIPTION OF WORK PERFORMED:
I replaced the broken tank lever and tested. During testing I found the fillvalve to be sticking on some flushes and the flapper was starting to warp. I replaced the fillvalve, flapper, and supply. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Discount Labour	\$99.00	\$99.00
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ	\$35.00	\$35.00
1	2121352	B1-16DL 3/8X20 SPEEDI+ WC CONN	\$11.00	\$11.00
1	GP85160	2" Flapper With Float	\$20.00	\$20.00
1		Tank Lever	\$12.00	\$12.00

Give us Feedback
 Please visit our feedback page at:
www.yaletownplumbing.com/feedback [1]
 Fill in the required details from your invoice and tell us how we did.
Thank You!

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.
TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$177.00
GST (5%):	\$8.85
TOTAL:	\$185.85

_____ 2017-11-20

 CUSTOMER SIGNATURE DATE