



DATE 2018-02-07	TECHNICIAN Darren Mann	JOB/ORDER # 8179	REFERENCE TEXT Client reference
FIRST NAME Vivian		LAST NAME Tong	
BILLING ADDRESS COMPANY / BILLING NAME 1011 W CORDOVA ST VANCOUVER, V6C0B2 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 3302 - 1011 W CORDOVA ST BUZZER: 3302 VANCOUVER, V6C0B2 BRITISH COLUMBIA, CANADA	
PHONE 778-895-2968		EMAIL vtong21@hotmail.com	

REASON FOR TODAY'S CALL:  
 Our \*Dornbracht shower fixture is broken. Specifically, it is the temperature control handle that is malfunctioning.

DESCRIPTION OF WORK PERFORMED:  
 I removed the Thermostatic cartridge, cleaned the inlet screens, reinstalled and calibrated. Tested and in good working order.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Recalibrate Dornbracht Thermostatic Cartridge	\$169.00	\$169.00

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:		\$169.00
GST (5%):		\$8.45
TOTAL:		\$177.45

  

 _____ CUSTOMER SIGNATURE	2018-02-07 _____ DATE
--	-----------------------------