



DATE 2018-03-13	TECHNICIAN Darren Mann	JOB/ORDER # 8297	REFERENCE TEXT
FIRST NAME Easyrent	LAST NAME Admin		
BILLING ADDRESS EASYRENT REAL ESTATE SERVICES LTD. 100 - 1290 HOMER ST VANCOUVER, V6B2Y5 BRITISH COLUMBIA, CANADA		SERVICE ADDRESS 2305 - 1199 MARINASIDE CR, BUZ#1325 TORR: 778.322.1206 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.662.3279		EMAIL info@easyrent.ca	

REASON FOR TODAY'S CALL:  
Toilet not flushing properly.

DESCRIPTION OF WORK PERFORMED:  
I replaced the toilet fillvalve, flapper, and supply line. I also pushed some buildup out of the hole in the bottom of the bowl that water comes out of during a flush. Tested by flushing large rolled up balls of toilet paper.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Discount Labour	\$99.00	\$99.00
1	2121352	B1-16DL 3/8X20 SPEEDI+ WC CONN	\$11.00	\$11.00
1	2465350	214L HORNET UNIV FLAPPER RBR	\$10.00	\$10.00
1	9520164	PRO45B ANTI-SYPH FILL VLV UQ	\$35.00	\$35.00

**Give us Feedback**  
 Please visit our feedback page at:  
[www.yaletownplumbing.com/feedback](http://www.yaletownplumbing.com/feedback) [1]  
 Fill in the required details from your invoice and tell us how we did.  
**Thank You!**

WARRANTY: **PARTS** - SUBJECT TO MANUFACTURER'S WARRANTY

**LABOUR** - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO WARRANTY ON CUSTOMER SUPPLIED MATERIALS.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING.  
**TERMS:** NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

SUBTOTAL:	\$155.00
GST (5%):	\$7.75
TOTAL:	\$162.75

\_\_\_\_\_ 2018-03-13  
 \_\_\_\_\_  
 CUSTOMER SIGNATURE DATE