



HST #837181627

**UNIT PRICE** 

**PRICE** 

DATE 2018-04-10	TECHNICIAN Darren Mann		JOB/OR 8371	RDER #	REFERENCE TEXT Client reference
FIRST NAME Easyrent		LAST NAME Admin			
BILLING ADDRESS EASYRENT REAL ESTATE SE 100 - 1290 HOMER ST VANCOUVER, V6B2Y5 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS  1802 - 550 PACIFIC ST, BUZ#1 EZGI: 604.499.0157 GOKHAN: 604.652.0427 VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.662.3279	-			EMAIL info@easyrent.ca	

## REASON FOR TODAY'S CALL:

Leaking kitchen faucet.

QTY.

## DESCRIPTION OF WORK PERFORMED:

CODE

-Apr10: I made a visit to the unit and found that the faucet was leaking internally from 2 spots. -Apr12: I returned with a new Moen pullout kitchen faucet but before I could replace the faucet I first had to repair the hot & Cold shut off valves under the sink(connected to the faucet) as they were not fully shutting the water off. I repaired these valves by replacing the washers, stems, packing, packing nuts, and handles. I then installed the new faucet and tested.

**DESCRIPTION** 

2	Discount Labour	\$99.00	\$198.00
1	Moen Pullout Kitchen Faucet	\$170.00	\$170.00
2	Repair 1/2" x 3/8" Angle or Straight Stop - ADD-ON	\$25.00	\$50.00
Gwe us Feedback WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY			\$418.00
Please visit our feedb	LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF	GST (5%):	\$20.90
www.yaletownplumbi Fill in the required de		TOTAL:	\$438.90

Thank You!

invoice and tell us how we did.

INTEREST AT THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS. ACKNOWLEDGEMENT IS HEREBY MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TERMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E.

2018-04-10 CUSTOMER SIGNATURE DATE